

ROAD SUPERINTENDENT

REPORT NO. R-05-2020 – JUNE 8, 2020

FOR THE MONTH OF MAY 2020

1. LOOSE TOP / GRAVEL ROAD 1320.

a) Dust control.

- May 6th: Conc.5, Duplantie Rd., Villeneuve Rd. & garage yard
- May 11th: Maple Row, Conc.6 W., Clement N. & S., Titley Rd.
- May 14th: Gibbs, Petite 14, McDonald & Lalonde-Martineau.
- May 20th: Conc1, Castors Rd., Lemieux Rd. N. & S.
- May 25th: Nixon N, St-Thomas, Moore, Cuning S and Stardale E.

b) Gravel resurfacing.

- May 19th; Conc. 1
- May 20th; Nixon Rd. and St-Thomas
- May 21st; Moore Rd. and Stardale E.
- May 25th; Stardale E. and Cuning N.
- May 26th, Cuning N. and Conc. 2
- May 27th, Conc. 2, spot on Ranger Rd. and Conway Rd.
- May 28th; Conway Rd, Greenlane Rd.

2. CONSTRUCTION

- a) Paving of Grande Montee between Conc. 5 and Conc. 7 May 12th - May 15th.
- b) Paving of Conc.7 between Quebec border and Mr. Miller May 19th-20th.
- c) Paving of Nixon Rd. between Domaine Rd. and Conc.3 May 22nd and May 27th.
- d) Paving of Cuning S. between Conc. 3and Cty. Rd. 10 May 28th and June 1st.

3. ROAD SIDE MAINTENANCE1340

- a) On May 11th, Post and guide rail repaired at the Conway overpass and on the 1st. Conc.

4. HARD TOP / PAVED ROADS 1310

- a) Approximately 5 mt. of cold mix material was use to patch potholes on all paved roads.
- b) Received 33.28 mt. of cold mix material from Bray construction

5. MACHINERY MAINTENANCE

- a) See attached sheet...

6. WATERWORKS

- a) May 5th, UV light at Ste-Anne Centre d'action was found faulty and some repair done by Confort water. They came back May 27th to fix the still faulty unit. The light assembly will need to be replace with a new unit since some parts are no longer available.

7. LOAD RESTRICTION

- a) May 1st, Load restriction lifted on all municipal roads

8. EMPLOYEE

- a) May 1st was the last day of Alex-Andre Cardinal as temporary winter employee.
- b) May 4th, Michel Normand starting is temporary summer position

9. ST-EUGENE SANITARY SEWER

- a) May 5th, Repair sanitary sewer connection at the main pipe for the house 1154 Labrosse st. The excavation was done using St-Eugene Backhoe; repair was done by the township employees. The re-paving was done May 13th.
- b) May 5th, found that the pumping station in St-Eugene need repair. Both pumps, floats and holding rods need to be repair. Repair is expected to be completed by the second week of June by OCWA.

10. HOLIDAY

- a) Trevor Holiday, May 11th-15th.

11. OPEN FOR DISCUSSION

- a) Employee inappropriate behavior _____
- b) _____
- c) _____

Jean-Francois Santerre
Road Superintendent

